



MOSIER WATER SYSTEM
EXISTING IMPROVEMENTS
 Dec. 2014

JOHN GRIM & ASSOCIATES
 Civil Engineering Consultants
 Phone: (509) 365-5421
 E-mail: jgrim@johngrimassociates.com
 PO Box 955
 407 State St.
 Lyle, Washington 98635

Date: Dec 3, 2014
 Current Water System Map.dwg
 Not to Scale

LEGEND	
	URBAN GROWTH BOUNDARY
	CITY LIMITS LINE
	WATERMAIN TO BE REPLACED.
	8-INCH WATERMAIN
	6-INCH WATERMAIN
	3-INCH AND 2-INCH WATERMAIN
	PRESSURE ZONE 312
	PRESSURE ZONE 400
	PRESSURE ZONE 436
	PRESSURE ZONE 600
	AREAS WITHIN THE 436 ZONE REQUIRING PRESSURE REGULATION

Mosier Bluffs BPS & PRV No. 2

Reservoir No. 4 (436 Zone)
 178,000 gallons

Reservoir No. 3 (600 Zone)
 Mosier Bluffs Tank
 56,000 gallons

CITY OF MOSIER
 WASCO COUNTY, OREGON